




Member of



Certificate of Conformity with European standards for Components and Systems

Number of Certificate

Valid from
dd-mm-yyyy

Valid until
dd-mm-yyyy

EN-ST-000251

01-05-2022

30-04-2026

Subject matter of Certificate:

**Magnetic contact grade 2
VS.B.06/10/25**

Owner of Certificate:

**Aug. Winkhaus GmbH & Co. KG
August-Winkhaus-Straße 31
48291 Telgte**

Basis for certification:

EN 50131-2-6:2008

Use, the product disposes of the following parameters:

Intrusion and hold-up systems, Grade 2

The tests were carried out at VdS Schadenverhütung GmbH
and the results are documented in **test report:**

STE 17/0464 dated 27-04-2018

VdS Schadenverhütung GmbH
Certification Body
Amsterdamer Str. 174
D-50735 Köln

A company of the German
Insurance Association (GDV)
accredited by DAkkS as certifica-
tion body for fire protection and
security products



To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises **4** pages and shall only be reproduced without any modifications and including all enclosures.

Date: 28-04-2022

Managing director

Head of certification body

To Certificate No.: EN-ST-000251

Date : 28.04.2022

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
Magnetic contact consisting of: - Magnetic switch with a moulded plastic enclosure and 6m, 10m or 25m connector cable - Magnet of NdFeB Ø 8 x 2 mm in the following contact transmitters: - Rigid - Rigid - Rigid - Moveable - Moveable	VS.B.06/10/25 VS.KGS.04 VS.KGS.06 VS.KG.04 E1.VS.KG.F MK.VS.150.KG		

To Certificate No.: EN-ST-000251

Date : 28.04.2022

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation instructions	996000241	04/2018	2
Specification	EWB 506645	26.03.2018	9
Data sheets:			
- VS.B.06		04.03.2010	1
- VS.B.25		04.03.2010	1
- VS.BK.06		04.03.2010	1
- Reed switch STW10		08.06.2011	1
- Reedschalter KSK-1C94		10.08.2017	1
- Cable 4 x 0,14 mm ² ,6m		07.06.2010	1
- Cable 4 x 0,14 mm ² ,25m		07.06.2010	1
- Cable 7 x 0,14 mm ² ,6m		07.06.2010	1
- Bar magnet Ø 8 x 2mm		24.02.2010	1
- WEVO grouting compound		11/2007	2
Construction drawing, lock-sensor VS.B...V1	Z01002325	14.01.2016	1



Enclosure 3

Sheet 1

To Certificate No.: EN-ST-000251

Date : 28.04.2022

Instructions for the application of the approval component/system (see enclosure 1):

1. The device is suitable for use in intruder alarm systems according to EN 50131-1.
2. The device complies with environmental class IIIA of EN 50131-2-6.